

SDG&E, June 15th, 2023

Rulemaking (R.) 15-01-008 to Adopt Rules and Procedures Governing Commission Regulated Natural Gas Pipelines and Facilities to Reduce Natural Gas Leaks
Consistent with Senate Bill 1371, Leno.
In Response to Data Request, R15-01-008 - 2023 June Report
Appendix 2; Rev. 03/30/2023

Notes:

Use a formula-derived value with the formula used in the Annual Emissions column. Do not use a copy and paste-as-value.

At the end of Annual Emissions Column, add a summation total in a cell for a column total, and then highlight orange.

Facilities emissions that are based on a population count times an emission factor (See Appendix 9 for guidance).

Transmission M&R Station Total Leaks and Emissions:

Number of Stations	Station Classification	Emission Factor (Mscf/yr/ <i>station</i>)	Annual Emission (Mscf)	Explanatory Notes / Comments
14	T	1,554.8	21,767.2	This includes stations that have Transmission to Distribution connections
2	F	12.2	24.4	Tap Facilities - Transmission Maintained. The two taps are blind-flanged and not connected to customers.
Sum Total			21,792	

Rulemaking (R.) 15-01-008 to Adopt Rules and Procedures Governing Commission Regulated Natural Gas Pipelines and Facilities to Reduce Natural Gas Leaks Consistent with Senate Bill 1371, Leno.
In Response to Data Request, R15-01-008 - 2023 June Report
Appendix 2; Rev. 03/30/2023

Note:
Use a formula-derived value with the formula used in the Annual Emissions column. Do not use a copy and paste-as-value.
At the end of Annual Emissions Column, add a summation total in a cell for a column total, and then highlight orange.

Transmission M&R Station Blowdowns:				
ID	Geographic Location	Number of Blowdown Events	Annual Emissions (Mscf)	Explanatory Notes / Comments
NA	SDG&E Territory	14	0.28	Pressure Limiting Station Annual Inspection - Estimated avg. gas vented = 20 scf/insp
NA	SDG&E Territory	41	0.82	Relief Valve Inspection at Transmission M&R Stations - Estimated avg. gas vented = 20 scf/insp (annual test with Nitrogen, gas vented is volume of gas in valve)
NA	SDG&E Territory	20	0.6	Filter Changeout or Filter Inspection w/parts replacement - Estimated avg. gas vented = 30 scf/ea
NA	SDG&E Territory	3	0.075	Analyzers (25 scf/inspection)
NA	SDG&E Territory	59	0.118	Controllers - Estimated avg. gas vented = 2 scf/insp
NA	SDG&E Territory	12	0.024	Actuators - Estimated avg. gas vented = 2 scf/insp
NA	SDG&E Territory	1	0.03	Drips (30 scf/insp)
NA	SDG&E Territory	7	0.014	Linebreaks - Estimated avg. gas vented = 2 scf/insp
NA	SDG&E Territory	4	0.08	Meters (20 scf/insp)
Sum Total			2	

Rulemaking (R.) 15-01-008 to Adopt Rules and Procedures Governing Commission Regulated Natural Gas Pipelines and Facilities to Reduce Natural Gas Leaks Consistent with Senate Bill 1371, Leno.
In Response to Data Request, R15-01-008 - 2023 June Report
Appendix 2; Rev. 03/30/2023

The data collected on this sheet is for informational purposes and may be included in the emissions inventory for 2021. The worksheet is designed to track actual emissions for future reference and to determine if an actual leak based emission accounting is feasible for M&R stations. Use a formula-derived value with the formula used in the Annual Emissions column. Do not use a copy and paste-a-value. At the end of Annual Emissions Column, add a summation total in a cell for a column total, and then highlight orange.

Transmission M&R Station Component Vented Emissions:

ID	Geographic Location	Station Classification	Device Type	Bleed Rate	Manufacturer	Number of Days Emitting	Annual Emissions (Mscf)	Explanatory Notes / Comments
24	SDG&E	A3	P	I	Misc.	365	NA	Intermittent Bleed Pneumatic Device emissions are included in Trans-to-trans Emission Factor of 1,554.8 Mscf/Station/Year
Sum Total							0	

Rulemaking (R) 15-01-008 to Adopt Rules and Procedures Governing Commission Regulated Natural Gas Pipelines and Facilities to Reduce Natural Gas Leaks Consistent with Senate Bill 1371, Leno.
In Response to Data Request, R15-01-008 - 2023 June Report
Appendix 2; Rev. 03/30/2023

At the end of Annual Emissions Column, add a summation total in a cell for a column total, and then highlight orange.

Transmission M&R Station Component Fugitive Leaks:

Station Emissions Data												Prior Survey Date (DD/MM/YYYY)	
ID	Geographic Location	Station Classification	Device Type	Bleed Rate	Manufacturer	Discovery Date (MM/DD/YYYY)	Repair Date (MM/DD/YYYY)	Number of Days Leaking	Emission Factor (lbac/day/lev)	Annual Emissions (lbac)	Explanatory Notes / Comments	Prior Survey Date (DD/MM/YYYY)	
8070496	92110 A1	A3	F			10/17/2022	10/19/2022	28	NA	NA	Component leaks at Transmission M&R Stations - Emissions are included in Transmission M&R Facilities Emission Factor of 1,554.8 Msc/Station/Year	9/22/2022	
8094494	92071 A2	A1	C			10/17/2022	10/17/2022	123	NA	NA	Component leaks at Transmission M&R Stations - Emissions are included in Transmission M&R Facilities Emission Factor of 1,554.8 Msc/Station/Year	6/17/2022	
Sum Total											0		

Appendix 2; Rev. 03/30/2023

Header column "Comment" boxes displayed below for reference.	
Column Heading	Description and Definition of Required Contents (IF not self-explanatory)
Station Leaks and Emissions	
Number of Stations	
Station Classification	D = direct sale T = transmission-to-transmissions interconnect As revised in 2021, enter Farm Taps in Appendix 5
Emission Factor (Mscf/yr)	
Annual Emission (Mscf)	
Explanatory Notes / Comments	
Blowdowns	
ID	
Geographic Location	GIS, zip code, or equivalent
Number of Blowdown Events	
Annual Emissions (Mscf)	
Explanatory Notes / Comments	
Component Vented Emissions	
Geographic Location	GIS, zip code, or equivalent
Station Classification	A1 = above grade, pressure <100 psi A2 = above grade, pressure =100-300 psi A3 = above grade, pressure >300 psi B1 = below grade, pressure <100 psi B2 = below grade, pressure =100-300 psi B3 = below grade, pressure >300 psi
Device Type	C = connector O = open-ended line M = meter P = pneumatic device PR = pressure relief valve V = valve
Bleed Rate	L = low bleed I = intermittent bleed H = high bleed NA = not applicable
Manufacturer	
Number of Days Emitting	Because the emissions are a factor of design or function, these emissions counted for the entire year.

Annual Emissions (Mscf)	<p>The emissions should be based on 365 days times the actual volume emitting if known, or the approved Emissions Factor.</p> <p>Note whether the emissions are based on actual volumetric measures in the next column.</p>
Explanatory Notes / Comments	
Component Fugitive Leaks	
ID	
Geographic Location	GIS, zip code, or equivalent
Station Classification	<p>A1 = above grade, pressure <100 psi A2 = above grade, pressure =100-300 psi A3 = above grade, pressure >300 psi B1 = below grade, pressure <100 psi B2 = below grade, pressure =100-300 psi B3 = below grade, pressure >300 psi</p>
Device Type	<p>C = connector O = open-ended line M = meter P = pneumatic device PR = pressure relief valve V = valve</p>
Bleed Rate	<p>L = low bleed I = intermittent bleed H = high bleed NA = not applicable</p>
Manufacturer	
Discovery Date (MM/DD/YY)	<p>List the actual discovery date.</p> <p>If the leak was discovered in the year of interest, then we will assume the component was leaking from the beginning of the year for emissions reporting purposes, or prior survey date if surveyed previously within the year of interest.</p>
Repair Date (MM/DD/YY)	Date that the component repair stopped the leak. Any associated blowdowns as a result of the repair should be included in the blowdowns tab.
Number of Days Leaking	<p>Assume Leaking from January 1 of subject year or prior survey date, whichever is later, thru the repair date (if repaired in year of interest) or December 31 of subject year, whichever is earlier.</p> <p>For O&M discovered leaks, assume that the leak begins with the discovery date <u>thru</u> repair date or December 31st of subject year, whichever is earlier.</p>

Emission Factor (Mscf/day/dev)	
Annual Emissions (Mscf)	
Explanatory Notes / Comments	